

Energy Saving Charter 2020 and 4T Charter Online Briefing Sessions

How to Conduct Indoor Temperature Measurement?



General Guidelines on Routine Air Temperature Measurements




Number of Sampling Points

- Measurements should be taken at **air-conditioned space**
(Each floor for multi-storey air-conditioned premises)
- One sampling point per 2,000 m²
- Two sampling points for area >4000 m²
- Sufficient number of samples for area <4000 m²



Example 1



Example 2



Example 3



Number of Sampling Points

Average indoor temperature is the
numerical average all sampling points



General Consideration for Selecting Locations for Measurement



Measurements shall be taken ...

- Occupied zones during the occupied hours
- The sampling locations should be representative locations



Measurements shall be taken ...

- In air-conditioned areas with both high and low occupancy rate
- At least 0.5 metre inward *from corners, windows, walls, doors*
- Not under direct sunlight
- At a height of 1.1 metres above the floor level for physical measurement



Measurements shall be taken ...

- Not directly in front of:
 - Air supply diffusers
 - Induction units
 - Floor fans
 - Heaters
 - Exhaled breath of the operators, lifts, escalators, entrance or exit, etc.





Measuring Instrument




By Electronic or Mechanical Thermometer

(Adequate measuring time, normally one minute)



Measuring Instrument

Should have a valid calibration certificate issued by an accredited laboratory of Hong Kong Laboratory Accreditation Scheme (HOKLAS).

 Hong Kong Calibration Ltd.
香港校正有限公司

Calibration Certificate

Certificate No. 90 [redacted] Page: 1 of 2 Pages

Customer: [redacted]
Address: [redacted] Kwun Tong, Kowloon.
Order No.: Q0 [redacted] Date of receipt: 18-Jun-19

Item Tested

Description: Humidity & Temperature Meter
Manufacturer: VAISALA
Model: HM 34
I.D.: [redacted]
Serial No.: 590136

Test Conditions

Date of Test: 24-Jun-19
Ambient Temperature: $(23 \pm 3)^{\circ}\text{C}$
Supply Voltage: [redacted]
Relative Humidity: $(50 \pm 25)\%$

Test Specifications

Calibration check.
Ref. Document/Procedure: T03, T08.

Test Results

All results were within the user's or manufacturer's specification.
The results are shown in the attached page(s).

Main Test equipment used:


Equipment No.	Description	Cert. No.	Traceable to
S223B	Std. Thermometer	[redacted]	NIM-PRC
S232	R.H. Standard	[redacted]	SCS-SWISS

The values given in this Calibration Certificate only relate to the values measured at the time of the test and any uncertainties quoted will not include allowance for the equipment long term drift, variations with environmental changes, vibration and shock during transportation, overloading, mis-handling, or the capability of any other laboratory to repeat the measurement. Hong Kong Calibration Ltd. shall not be liable for any loss or damage resulting from the use of the equipment.

The test equipment used for calibration are traceable to International System of Units (SI), or by reference to a natural constant.
The test results apply to the above Unit-Under-Test only

Calibrated by: [redacted] Approved by: [redacted]
Date: 25-Jun-19

This Certificate is issued by
Hong Kong Calibration Ltd.
Unit B5, 24/F., Wei Fung Industrial Centre, No. 18-75, Tai Cheun Ping Street, Kwai Chung, NT, Hong Kong.
Tel: 2425 8801 Fax: 2425 9545
The copyright of this certificate is owned by Hong Kong Calibration Ltd. It may not be reproduced except in full.



Temperature Record

- Temperature readings captured by the BMS
- Seek assistance from building management offices for capturing air temperature reading





Temperature Record



Records of Temperature Measurement

- Measurement suggested to be taken at least twice a week
- Keep a record of the routine temperature measurements for future reference and review




Site Visit Record

Year	Site No.
2017	58
2018	63
2019	63

Venue selected
for temperature
checking is on
randomly basis

Temperature
measurement will
only be taken at the
area where signed
up the Charter



Example of Temperature Measurement Record



Example (G/F)

Location	Measured Temperature (°C)
Lift Lobby	24.3
G03	24.5

Average Indoor Temperature for G/F
(2 point) : 24.4°C




Example (1/F)

Location	Measured Temperature (°C)
103A	23.8
121	24.0
132	24.2
116A&B	24.6
112	23.9

Average Indoor Temperature for
1/F (5 points) : 24.1°C

Average Indoor Temperature
of the shopping mall
(G/F and 1/F, 7 points): 24.2°C





◎ 約章計劃

◎ 參與者

◎ 節能有計

◎ 4T有計

◎ 宣傳活動及推廣資料

◎ 有用資料

節能有計

2020



節能有計

(1) 室內平均溫度維持在攝氏24至26度之間

- 量度溫度可參考量度溫度的一般指引。
- 空調設備開啟時應關閉窗戶。
- 利用門作為空調區域之間的分隔（如升降機大堂、洗手間及商店等連接戶外的地方），以減低使用空調設備時的空氣滲入。並請關好凍櫃門。

(2) 關掉不使用的電器

- 在不使用的區域，關掉空調機關掉。若辦公室人數不多，應將非必要的照明設備關掉及採用工作燈直接照明工作的地方。
- 在非繁忙時間期間，關閉部份升降機及自動梯。
- 選用附有時間制或節能模式的電器，以免電器長期停留在備用狀態。在不使用時，應將電器及變壓器由插座拔除。請參閱減少備用狀態耗能小冊子。

For More Information:

<https://www.energysaving.gov.hk/es/c2020/tc/tips/index.html#item1>





Thank You

